



The City of Flin Flon

**PUBLIC WATER SYSTEM  
ANNUAL REPORT**

**2019**

Contact Person:	James REITLO, Operations Supervisor Utility Structures
Phone:	(204) 687-0499
E-mail:	<a href="mailto:jreitlo@flinflon.ca">jreitlo@flinflon.ca</a>
Emergency Number:	687-0676
Business Phone:	(204) 681-7511 (City Hall)
Date Prepared:	January 20, 2019

## **Description of the Water System**

The City of Flin Flon Public Water System provides potable water to approximately 5,185 persons, about 203 of which live in Flin Flon, Saskatchewan (Statistics Canada 2016 Census). With the new Water Treatment Plant being online as of August 2013, treated water currently meets most health and aesthetic objectives as regulated by the Guidelines for Canadian Drinking Water Quality.

### **Water Supply Source**

The City of Flin Flon Cliff Lake Pumphouse receives water from Cliff Lake, located approximately 2200 m north of the Water Treatment Plant (WTP). Raw water is pumped through twin feeder mains (installed in 2008) from the Cliff Lake Pumphouse to the new Water Treatment Plant.

### **Water Treatment Process**

The current treatment process consists of chlorination – chlorine is added to the water at two points – the first is located at the Water Treatment Plant, and uses chlorine gas, and the second is a sodium hypochlorite port located at No. 1 Heating Plant. The new Water Treatment Plant utilizes an ultrafiltration system to purify the water, prior to chlorination for disinfection.

The new treatment process consists of raw water flash mixing with Aluminum Chlorohydrate and flocculation before splitting to feed two ultrafiltration process trains to purify the water. These processes are designed to clarify the water and remove microbial contaminants, such as bacteria, and organic materials that are naturally found in surface waters before chlorination. The filtered water is chlorinated using chlorine gas and pH adjustment is achieved with Sodium Hydroxide (Caustic Soda) before being stored below the Water Treatment Plant in the dual cell 4,000 m<sup>3</sup> storage reservoir. Chlorination is adjusted using sodium hypochlorite port located at No. 1 Heating Plant.

### **Distribution System**

The City of Flin Flon's distribution system currently consists of a raw water pumphouse, 2 supply mains, water treatment plant (including below ground reservoir, distribution/re-circulation/heating plant), a ground level reservoir, 1 heating/re-circulating plant, 1 secondary distribution plant, and a double main re-circulating system.

Water from the Cliff Lake Water Pumphouse is pumped to the Water Treatment Plant, which is the first distribution point. Water is then pumped from the Water Treatment Plant to the Hill Top Reservoir which supplies No. 1 Heating Plant as a distribution point, and No. 3 Heating Plant as a secondary distribution point.

The distribution system is a double main re-circulating system which is fed by supply mains to all connections. Return mains bring unused water back to a common header where this water is then re-distributed by the supply mains. Due to above ground and shallow bury water mains, the re-circulation is required to keep the water moving so it will not freeze during the winter months.

The distribution piping is mainly comprised of cast iron, ductile iron, PVC, polyethylene, and copper.

### **Storage Reservoirs**

Water Reservoir	Capacity	675,000 gallons (3,068 m <sup>3</sup> )
Water Treatment Plant	Capacity	879,877 gallons (4,000 m <sup>3</sup> )

Total water storage represents approximately 1 day of potable water storage.

### **Number of Connections, Population Served and Types of Water Users**

The City of Flin Flon is comprised of approximately 2280 service connections, 303 of which are metered, and the remaining are residential flat rate accounts. Rates were increased by 3.0% in 2016.

**Description of the Water System** cont'd.

**Classification and Certification**

Under Regulation 77/2003, Water and Wastewater Facility Operators Regulation, The Environment Act, C.C.S.M. E125, the Province requires every Provider of water to have its system classified. It is the responsibility of the Provider to ensure its employees have minimum certification level, to the classified level of its systems. The City of Flin Flon's water facilities have the following classifications:

Class 3 Water Treatment Facility Classification and Class 2 Water Distribution Facility Classification

The City of Flin Flon's employees are certified as follows:

<b>Employee</b>	<b>Water Treatment</b>	<b>Water Distribution</b>
James REITLO	Class III	Class II
Jon EVANS	Class II	Class II
Mike WESEEN	Class II	Class II
Jon SMALLEY		Class II
Tyler BOUTEILLER	Class II	Class II
Michelle FLICK		Class II

**Disinfection System In Use**

The City of Flin Flon uses chlorine as its only form of disinfection. Sodium hypochlorite port located at No. 1 Heating Plant boosts the chlorine residual in the distribution system.

As per The Drinking Water Safety Act, The City of Flin Flon must ensure that a disinfection residual of at least:

0.5 mg of free chlorine per litre of water is detectable at the point where water enters the distribution system, after a minimum contact time of 20 minutes.

0.1 mg of free chlorine per litre is detectable at all times at any point in the distribution network.

**Type of Disinfection System Used**

Chlorine is injected at 2 points in the distribution system – Water Treatment Plant, where chlorine gas is injected directly into the treated water before it enters the clear well; and No. 1 Heating Plant, where sodium hypochlorite 12% is injected via a single chlorine injection pump.

**Equipment Redundancy & Monitoring Requirements**

The overall operational reliability of the system is very good. The operation reliability is likely attributable to the level of competence of the operations and maintenance staff, as well as some redundancies built into the system. Much of the critical equipment has inline spares as per the requirements of The Drinking Water Safety Act. The City of Flin Flon ensures continuous disinfection is maintained.

Disinfectant residuals are monitored continuously at the Water Treatment Plant and entering the distribution system. Disinfectant residuals in the distribution system are also manually tested daily and recorded on the appropriate monitoring forms. Monthly Chlorination Forms are sent to the regional Drinking Water Officer at the end of each month.

**Disinfectant Residual Overall Performance/Results**

For 2019, The City of Flin Flon met all regulatory requirements in regards to monitoring and reporting disinfection residuals leaving the Water Treatment Plant and in the distribution system 100% of the time. The requirement to have free chlorine residual entering the distribution system was met in excess of 100% of the time, and at no time was the water tested and found to have zero chlorine residual (i.e. less than 0.10 mg/L).

## List of Water Quality Standards

In accordance with water quality standards adopted by the Province of Manitoba, the 2018 results for The City of Flin Flon Public Water System are summarized in the following table:

Testing Parameter	Standard	Frequency	Test	
Bacteriological – Treated Water	0 Total coliforms/100 mL	Bi-weekly		100%
	0 <i>E.coli</i> /100 mL	Bi-weekly		100%
Bacteriological – Distributed Water	0 Total coliforms/100 mL	Bi-weekly		100%
	0 <i>E.coli</i> /100 mL	Bi-weekly		100%
Chlorine (Treatment Plant)	0.5 mg/L	Daily		100%
Chlorine (Within Water Distribution System)	0.1 mg/L	Daily		100%
Trihalomethanes (THMs) (incl. Bromodichloromethane, bromoform, chloroform,	0.1 mg/L	Quarterly Average		100%
Haloacetic Acids (HAAs)	0.08 mg/L	Quarterly Average		100%
			Untreated Test Results	Treated Test
Lead	0.005 mg/L	Annually	0.000128mg/L	<0.000050 mg/L
Antimony	0.006 mg/L	Annually	0.00019 mg/L	<0.00019 mg/L
Arsenic	0.010 mg/L	Annually	0.00262 mg/L	0.0092 mg/L
Barium	1.0 mg/L	Annually	0.00975 mg/L	0.00914 mg/L
Boron	5.0 mg/L	Annually	<0.010 mg/L	<0.010 mg/L
Cadmium	0.005 mg/L	Annually	0.000349 mg/L	0.000208 mg/L
Chromium	0.05 mg/L	Annually	<0.00010 mg/L	<0.00010 mg/L
Dissolved Fluoride	1.5 mg/L	Annually	0.063 mg/L	<0.053 mg/L
Nitrate N	10 mg/L	Annually	0.0071 mg/L	0.0102 mg/L
Nitrite N	1 mg/L	Annually	<0.0010 mg/L	<0.0010 mg/L
Selenium	0.05 mg/L	Annually	<0.000282 mg/L	<0.000170 mg/L
Uranium	0.02 mg/L	Annually	<0.000031 mg/L	<0.000010 mg/L
Turbidity			1.69 NTU	0.05 NTU

### TRIHALOMETHANES

Sample Date	Test	#1 HP Return	#1 HP Average	Mile 84 Return	Mile 84 Average	Guide Limit
February 20, 2018	1	0.070		0.058		
May 15, 2018	2	0.085		0.070		
August 28, 2018	3	0.146		0.120		
December 18, 2018	4	0.097		0.075		
February 26, 2019	1	0.056	0.096	0.045	0.077	0.100
May 23, 2019	2	0.086	0.096	0.074	0.079	0.100
August 8, 2019	3	0.116	0.089	0.106	0.075	0.100
November 26, 2019	4	0.089	0.087	0.068	0.073	0.100

Total Trihalomethanes (THMs) – Less than or equal to 0.10 mg/L as locational running annual average of quarterly samples.

**List of Water Quality Standards**

cont'd.

**Haloacetic Acids**

Sample Date	Test	#1 HP Return	#1 HP Average	Mile 84 Return	Mile 84 Average	Guide Limit
February 20, 2018	1	0.053		0.048		
May 15, 2018	2	0.066		0.059		
August 28, 2018	3	0.060		0.061		
December 18, 2018	4	0.042		0.035		
February 26, 2019	1	0.037	0.051	0.034	0.047	0.080
May 23, 2019	2	0.043	0.045	0.037	0.042	0.080
August 8, 2019	3	0.061	0.046	0.054	0.040	0.080
November 26, 2019	4	0.050	0.048	0.041	0.041	0.080

Total Haloacetic Acids 5 – Less than or equal to 0.08 mg/L as locational running annual average of quarterly samples.

**Water System Incidents & Corrective Actions**

None